

Testing laboratory

rue de Westhouse
B.P. 10
67235 BENFELD Cedex
Tel. (33) 03 88 57 41 41 - Telex 870 844
Fax (33) 03 88 57 42 20

ATTESTATION OF CONFORMITY No AC 9614 SYS

Following specifications :

International standard IEC 60439-1 (1999)

TESTED MATERIAL

Designation : Mounting and Cabling Accessories
Busbars Supports
Type : SBP 30
Manufacturer : SOCOMEC S.A. 67230 BENFELD France

Rated characteristics :

The above – mentioned products satisfy to the clearances and creepage distances required by the IEC 60439-1 for the rated insulation voltage U_i and rated operational voltage U_e declared by the manufacturer, subject to setting up by respecting the specifications of the standard. These products are sized up according to the calculation rules of IEC 60865-1 to satisfy to the requirements of the short-circuit tests of IEC 60439-1. However, only a type test carried out on an assembly representative of the real installation configuration allows to deliver a document that recognize the conformity to the standard requirements.

Enclosures : /


Date : August 17th, 2005

The writer


Dominique HESSMANN



Test, Standard and Certification
manager


Dominique MARBACH