

Testing laboratory
rue de Westhouse
B.P. 10
67230 BENFELD
Tel. (33) 03 88 57 41 41 - Telex 870 844
Fax (33) 03 88 57 42 20

ATTESTATION OF PERFORMANCE No AP 8927 SYS**Following specifications :**

Manufacturer specifications according to IEC 60439-1

TESTED MATERIAL

Designation : Mounting accessories
Type : Busbar supports
Rating : SBE 44
Manufacturer : SOCOMEC S.A. 67230 BENFELD FRANCE


Rated characteristics :

The above-mentioned material have been submitted to the tests according to IEC 60439-1 standard.

The test results are in the attached table

Date :

The writer



Dominique HESSMANN



Tests standard and certification manager


Dominique MARBACH

TESTED MATERIAL	TEST RESULTS
Busbar support SBE 44	SHORT CIRCUIT WITHSTAND TEST <u>Test current</u> : 10 kA rms <u>Power factor</u> : ≤ 0.2 <u>Test duration</u> : 100 ms <u>Distance between supports</u> : 800 mm <u>Observations</u> : Good Withstand
Busbar support SBE 44	IMPULSE VOLTAGE TEST (According to IEC60947-1) <u>Impulse voltage (Uimp)</u> : 12 kV <u>Observations</u> : Good Withstand
Busbar support SBE 44	GLOW WIRE TEST (According to IEC60695-2-1) <u>Test temperature</u> : 960 °C <u>Observations</u> : No flaming or glowing during the test
Busbar support SBE 44	DIELECTRIC TEST 50 Hz 1 min <u>Test voltage</u> : 10 kV - 50 Hz - 1 min. <u>Observations</u> : Good Withstand
Busbar support SBE 44	COMPARATIVE TRACKING INDEX (According to IEC 112) <u>Material group</u> : IIIa <u>Test voltage</u> : 225 V <u>Number of drops</u> : 55 <u>Observations</u> : Good Withstand