

Testing laboratory

Pierre SIAT

67230 BENFELD FRANCE

TESTING REPORT

N° : TR 8939 SYS

Page : 1/20

TESTED MATERIAL

Designation : Busbar support system SBC-30

Manufacturer: SOCOMEC S.A.
1-4, route de Westhouse
67230 BENFELD FRANCE

TESTS SUBJECT

Date of tests : 22nd and 28th of january 2003
Applicant : SOCOMEC S.A.
According to : The international standard CEI 60439-1 (1999)

Low-voltage switchgear and controlgear assemblies
Part 1 :
Type-tested and partially type-tested assemblies

In presence of : /

CONTENT OF THE TESTING REPORT

Presentation of the tested material	page(s) : 2
Tests program	page(s) : 3
Tests circuits diagrams	page(s) : 8
Calibration of the tests circuits	page(s) : 4 & 6
Tests results	page(s) : 5 & 7
Recordings	page(s) : 9 to 14
Photographies	page(s) : 15 to 19
Drawing	page(s) : 20

The tests results obtained during the tests written down in this report justify the rated characteristics given in page 2

Date : 1st of april 2003

The writer


Dominique HESSMANN



The testing manager


Denis HAENSEL

socomec s.a. au capital de 11 406 650 € - strasbourg B 548 500 149 - siret 548 500 149 00016 - c.c.p. strasbourg 7180 p
siège social : 1-4, rue de Westhouse - boîte postale 10 - 67230 Benfeld France - tél. 03 88 57 41 41 - télécopie 03 88 57 78 78 - Site Web : www.socomec.fr

CHARACTERISTICS AND PRESENTATION OF THE TESTING MATERIAL

Commercial designation : Busbar support system SBC-30

Description-presentation : Edgewise mounting busbar support system :

Bar thickness : 10 mm

Bar height : 160 mm

Bar material : Bare copper Cu-ETP (CUA1H12)

Interphase : 185 mm

Number of bars per phase : 3

Number of poles : 3

1st configuration tested : Distance between supports = 300 mm

2nd configuration tested : Distance between supports = 600 mm

Rated short-time current (I_{cw}) : 80 kA rms during 1 s

Rated peak withstand current (I_{pk}) : 176 kA peak

Rated frequency : 50 Hz

Dimensions drawings : S690033.TDP on page 20

TESTS PROGRAM

Reference of the test samples	Date of reception	Tests carried out	Date of test	pages
KLI/210103/02	21/01/03	<u>1st configuration : distance between supports = 300 mm</u>		
		<i>Test n° 1</i> Verification of rated short-time current I _{cw} = 30 kA 1 s Verification of rated peak withstand current I _{pk} = 63 kA peak	22/01/03	4 & 5
		<i>Test n° 2</i> Verification of rated short-time current I _{cw} = 50 kA 1 s Verification of rated peak withstand current I _{pk} = 105 kA peak	22/01/03	4 & 5
		<i>Test n° 3</i> Verification of rated short-time current I _{cw} = 80 kA 1 s Verification of rated peak withstand current I _{pk} = 176 kA peak	28/01/03	4 & 5
		<u>2nd configuration : distance between supports = 600 mm</u>		
		<i>Test n° 1</i> Verification of rated short-time current I _{cw} = 50 kA 1 s Verification of rated peak withstand current I _{pk} = 105 kA peak	28/01/03	6 & 7
		<i>Test n° 2</i> Verification of rated short-time current I _{cw} = 60 kA 1 s Verification of rated peak withstand current I _{pk} = 132 kA peak	28/01/03	6 & 7
		<i>Test n° 3</i> Verification of rated short-time current I _{cw} = 80 kA 1 s Verification of rated peak withstand current I _{pk} = 176 kA peak	28/01/03	6 & 7